



Transient Report

Recording Start Date 17.11.2011 - 11:18:54
Recording Duration 1 (s)
Instrument ID Model 8334 - 1 1:301079 3.0



Name	Date	Time	RMS	Units
4Cycles V2	17.11.2011	11:18:54.237	220.83	V
4Cycles V1	17.11.2011	11:18:54.237	221.87	V
4Cycles I1	17.11.2011	11:18:54.237	19.874	A
4Cycles I2	17.11.2011	11:18:54.237	19.537	A

17.11.2011 - 11:18:54.237
Val
-268.0 — 4Cycles V2
-269.0 — 4Cycles V1
-22.00 — 4Cycles I1
-24.00 — 4Cycles I2



Start Date: 17.11.2011
Start Time: 11:18:54.257
Duration: 2.500 (mS)
Frequency: 50.01 Hz
Magnitude Of Transient: 92.19
Data Point Of Transient: 31.00
VoltageRatio: 1.000
CurrentRatio: 1.000
Threshold V: 0 %
Threshold I: 0 %

Name	Date	Time	Duration	Units
Transient Trigger V2	17.11.2011	11:18:54.257	2.510	(mS)

17.11.2011 - 11:18:54.257
Val
-268.0 — Transient Trigger V2