



Transient Report

Recording Start Date 11.08.2011 - 10:55:40
Recording Duration 1 (s)
Instrument ID Model 8334 - 1 1:301079 3.0



Name	Date	Time	RMS	Units
4Cycles V2	11.08.2011	10:55:40.189	223.06	V
4Cycles V1	11.08.2011	10:55:40.189	239.18	V
4Cycles I1	11.08.2011	10:55:40.189	0.166	A
4Cycles I2	11.08.2011	10:55:40.189	0.153	A

11.08.2011 - 10:55:40.189
Val
-36.00 — 4Cycles V2
-32.00 — 4Cycles V1
0.119 — 4Cycles I1
97.00m — 4Cycles I2



Start Date: 11.08.2011
Start Time: 10:55:40.209
Duration: 2.499 (mS)
Frequency: 50.02 Hz
Magnitude Of Transient: -26.19
Data Point Of Transient: 10.00
VoltageRatio: 1.000000
CurrentRatio: 1.000000
Threshold V: 0 %
Threshold I: 0 %


Name	Date	Time	Duration	Units
Transient Trigger V2	11.08.2011	10:55:40.209	2.509	(mS)

11.08.2011 - 10:55:40.209
Val
-29.00 — Transient Trigger V2

Channel Name: Waveform V2

Frequency: 50.02 Hz

VoltageRatio: 1.000000




11.08.2011
10:55:40.189

19.992 (mS)
3 mSec/Div

11.08.2011
10:55:40.209

Name	Date	Time	Duration	RMS	Units
Waveform V1	11.08.2011	10:55:40.189	20.002	232.25	V
Waveform V1	11.08.2011	10:55:40.209	20.002	237.19	V
Waveform V1	11.08.2011	10:55:40.229	20.002	241.74	V
Waveform V1	11.08.2011	10:55:40.249	20.002	245.35	V
Waveform V2	11.08.2011	10:55:40.189	20.002	222.96	V
Waveform V2	11.08.2011	10:55:40.209	20.002	223.08	V
Waveform V2	11.08.2011	10:55:40.229	20.002	223.12	V
Waveform V2	11.08.2011	10:55:40.249	20.002	223.09	V



11.08.2011 - 10:55:40.189

Val

-32.00 — Waveform V1
-36.00 — Waveform V2


Waveform V2

(%)	(%)	(%)
H01 100.0	H19 0.2	H37 0.4
H02 0.4	H20 0.2	H38 0.2
H03 0.6	H21 0.1	H39 0.4
H04 0.2	H22 0.1	H40 0.2
H05 0.2	H23 0.1	H41 0.1
H06 0.2	H24 0.1	H42 0.1
H07 0.5	H25 0.3	H43 0.0
H08 0.2	H26 0.2	H44 0.1
H09 0.2	H27 0.3	H45 0.2
H10 0.2	H28 0.1	H46 0.1
H11 0.3	H29 0.0	H47 0.2
H12 0.2	H30 0.1	H48 0.1
H13 0.4	H31 0.4	H49 0.1
H14 0.2	H32 0.2	H50 0.1
H15 0.1	H33 0.4	
H16 0.2	H34 0.1	
H17 0.2	H35 0.1	
H18 0.2	H36 0.1	


Channel Name: Waveform I1

Frequency: 50.02 Hz

CurrentRatio: 1.000000



Name	Date	Time	Duration	RMS	Units
Waveform I1	11.08.2011	10:55:40.189	20.002	0.161	A
Waveform I1	11.08.2011	10:55:40.209	20.002	0.165	A
Waveform I1	11.08.2011	10:55:40.229	20.002	0.168	A
Waveform I1	11.08.2011	10:55:40.249	20.002	0.171	A
Waveform I2	11.08.2011	10:55:40.189	20.002	0.149	A
Waveform I2	11.08.2011	10:55:40.209	20.002	0.152	A
Waveform I2	11.08.2011	10:55:40.229	20.002	0.155	A
Waveform I2	11.08.2011	10:55:40.249	20.002	0.157	A



11.08.2011 - 10:55:40.189

Val

0.119 — Waveform I1

97.00m — Waveform I2

Waveform I1

(%)	(%)	(%)
H01 100.0	H19 0.3	H37 0.1
H02 0.2	H20 1.5	H38 0.1
H03 1.1	H21 1.1	H39 0.1
H04 0.3	H22 0.4	H40 0.1
H05 1.0	H23 0.2	H41 0.4
H06 0.2	H24 0.3	H42 0.2
H07 0.5	H25 0.3	H43 0.1
H08 0.1	H26 0.1	H44 0.1
H09 0.7	H27 0.2	H45 0.1
H10 0.1	H28 0.2	H46 0.1
H11 0.1	H29 0.1	H47 0.2
H12 0.1	H30 0.0	H48 0.2
H13 0.3	H31 0.2	H49 0.1
H14 0.2	H32 0.1	H50 0.2
H15 0.1	H33 0.3	
H16 0.3	H34 0.2	
H17 0.2	H35 0.2	
H18 0.3	H36 0.1	

Transient Report

Database: E:\èçìåðåíëÿ\VOLTER ETALON\Transient AA11.dvb

Operator

Test Site

Comments

